



मोबा-09473942594
email-upjnmzn@gmail.com

कार्यालय

अधिकासी अभियन्ता, खण्ड कार्यालय, उत्तर प्रदेश जल निगम (ग्रामीण)
464/47 दक्षिणी सिविल लाईन, कम्पनी बाग के पीछे, मुजफ्फरनगर

पत्रांक

1301

/ 103

/ 80

दिनांक:- 20/04/2026

ई-मेल द्वारा

सेवा में,

Watan Public School
Sandhawali, Muzaffarnagar (U.P.)

विषय:-जनपदीय प्रयोगशाला मुजफ्फरनगर में जल परीक्षण हेतु जमा कराए गए जल नमूने की परीक्षण रिपोर्ट के सम्बन्ध में ।

महोदय,


उपरोक्त विषयक आपके पत्रांक MUZU09026151666 दिनांक 02.04.2026 के सन्दर्भ में अवगत कराना है कि जनपदीय प्रयोगशाला मुजफ्फरनगर में दिनांक 06-04-2026 को जमा कराए गए 01 नमूने जल नमूने की परीक्षण रिपोर्ट सलंगन कर प्रेषित है।

सलंगनक -जल नमूने की परीक्षण रिपोर्ट ।

भवदीय

8/20/4/26
(सजय कुमार)

अधिकासी अभियन्ता


CHAIRMAN
WATAN PUBLIC SCHOOL
Sandhawali, Muzaffarnagar (U.P.)


PRINCIPAL
WATAN PUBLIC SCHOOL
Sandhawali, Muzaffarnagar (U.P.)



District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural) Muzaffarnagar
Address- Office of Executive Engineer, Khand Karyalay, U.P Jal Nigam (Rural), 464/47, South civil Line,
Muzaffarnagar, U.P. Pin-251001,

Water Test Report

Report No:	MZN/W/20260275M0012	Date:	09-04-2026	Page No	01/01
Remark: Sample collected by client. Laboratory did not verify source of sample submitted.					
Customer Name	Mohamed Asadullah Chairman, Watan Public School Sandhawali				
Office Name and Address	Office of the principal watan public school, NH-58, Sandhawali, Muzaffarnagar, U.P				
Ref. Letter No. & Date	02-04-2026, MUZU09026151666				
Basic details of sample					
District	Muzaffarnagar	Block	Sadar		
Gram Panchayat	Sandhawali	Village/Mohalla	Sandhawali		
Habitation	Sandhawali	Location/Site name	Watan Public School		
Water Source	Submersible	Sample No.	12		
Quantity of sample (ml)	1000ml	Date of sample collection	08-04-2026		
Receiving date	08-04-2026	Sample Collector	Mohamed Asadullah		
Sample depositor	Mohamed Asadullah	Sampling Method	As per Customer		
Analysis Start date	09-04-2026	Analysis Completion date	09-04-2026		

Technical Data of Analysis

S.No.	Analyzed parameters	Unit	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025(Part 5): 2022
2	pH @ 25°C	-	7.43	6.5-8.5	6.5-8.5	IS 3025(Part 11): 2022
3	Colour	Hazen	4.00	5.0	15.0	IS 3025(Part 4): 2021
4	Total Dissolved Solids	mg/L	1256.00	500	2000	IS 3025(Part 16): 2023
5	Chloride	mg/L	14.97	250	1000	IS 3025(Part 32): 2025
6	Total Alkalinity	mg/L	247.87	200	600	IS 3025(Part 23): 2023
7	Total Hardness	mg/L	250.60	200	600	IS 3025(Part 21): 2023
8	Nitrate	mg/L	0.45	45.0	45.0	APHA 24 th Edition 4500- NO ₃ Method-D (UV Screening): 2023
9	Fluoride	mg/L	0.562	1.0	1.5	APHA 24 th Edition 4500- F Method-C (Electrode Method) 2023
10	Iron	mg/L	0.077	1.0	1.0	APHA 24 th Edition 3500- Fe Method-B (1,10Phenanthroline): 2023
11	Calcium	mg/L	66.27	75.0	200	IS 3025(Part 40): 2024
12	Magnesium	mg/L	20.69	30.0	100	IS 3025(Part 46): 2023 (Calculation Method)
13	Free residual chlorine*	mg/L	0.0	0.2	1.0	IS 3025(Part 26): 2021
14	Turbidity*	NTU	NT	1.0	5.0	IS 3025(Part 10): 2023
15	Conductivity*	mS/cm	0.525			IS 3025(Part 14): 2023
16	Total coliform*	CFU	0.0	Shall not be detected in 100 ml sample	Shall not be detected in 100 ml sample	IS 15185 2016
17	E.Coli*	CFU	0.0	Shall not be detected in 100 ml sample	Shall not be detected in 100 ml sample	IS 15185 2016

B.D.L= Below Detection limit, N.T= Not Tested
* Mark Parameters are out of NABL Scope.

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified

Reviewed by

Authorized Signatory

(Deputy Technical Manager)

(Chemist/Quality/Technical Manager)

Laboratory Contact details:

Email ID: upjnman@gmail.com, Mob No: 8267922026

*****End of Report*****

CHAIRMAN
WATAN PUBLIC SCHOOL
Sandhawali, Muzaffarnagar (U.P.)

PRINCIPAL
WATAN PUBLIC SCHOOL
Sandhawali, Muzaffarnagar (U.P.)